

Software Name: ioLogik E4200 firmware

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/Enhancements	Bugs Fixed/Changes	Note
1.5	Build14011615	N/A	ioLogik E4200	<b>New features:</b> 1. Support MOXA Oncell 2111 and Oncell 2151 <b>Enhancements:</b> 1. Mail address setting can without Login name & Login Password information. 2. Improve default gateway setting in Modular ioAdmin for ioLogik E4200 firmware V1.4 or later only.	<b>Bugs Fixed:</b> 1. RTC Power on initial 2. Fix that flash could crash while power cycling. 3. Fix default gateway setting issue on web console	Improvement of default gateway setting works with the Modular-ioAdmin V1.5 or later only
1.4	Build12091212	N/A	ioLogik E4200	<b>Enhancements:</b> 1. Add CGI command status in web console 2. Improve default gateway setting in Modular ioAdmin and web console.	<b>Bugs Fixed:</b> 1. Fixed DNS refresh cause fresh data error. 2. Fixed Webpage cannot show data while Flash data updating 3. Fixed AOPC & web console cannot use in the same time.	Improvement of default gateway setting works with the Modular-ioAdmin V1.5 or later only
1.3	Build11060216	N/A	ioLogik E4200	<b>Enhancements:</b> 1. Added Modbus Address Function Code=0x08 for "ECHO" function. 2. Increased the maximum length of the email account and password fields in Click&Go to 39 characters.	<b>Bugs Fixed:</b> 1. The text between '<' and '>' should not be removed in message content. 2. Triggering remote action in every specific time should not be triggered again during this period of time. 3. Removed Modbus/TCP ID checking mechanism.	This firmware version works with the Modular-ioAdmin V1.3 or later only