



## Firmware for ioLogik E1200 Series (ioLogik E1240/E1240-T) Release Notes

<b>Version:</b> v3.3	<b>Build:</b> Build 22072210
<b>Release Date:</b> Aug 03, 2022	

### Applicable Products

ioLogik E1240, ioLogik E1240-T

### Supported Operating Systems

N/A

### New Features

- Adds the default password "moxa".
- Adds a Password and Login Policy.
- Adds the Notification Message function.

### Enhancements

- Adds the DHCP Option 12 "Server Name".

### Bugs Fixed

- Ethernet/IP cannot establish second input-only session.
- Ethernet frame padding information leakage (Etherleak).

### Changes

N/A

### Notes

N/A



<b>Version: v3.2</b>	<b>Build: Build20111915</b>
<b>Release Date: Dec 25, 2020</b>	

**Applicable Products**

ioLogik E1240-T, ioLogik E1240

**Supported Operating Systems**

N/A

**New Features**

- Safe Mode supports Ethernet/IP protocol.

**Enhancements**

N/A

**Bugs Fixed**

- DHCP mode will not get the Gateway IP.
- The serial number is displayed incorrectly on the web console.
- Ethernet/IP implicit messages are sent to port 2222 by default.

**Changes**

N/A

**Notes**

N/A



<b>Version: v3.1</b>	<b>Build: N/A</b>
<b>Release Date: Nov 26, 2019</b>	

### **Applicable Products**

ioLogik E1240, ioLogik E1240-T

### **Supported Operating Systems**

N/A

### **New Features**

- EtherNet/IP registration on Moxa's licensing website is no longer required.
- Added case insensitive content-length for RESTful API.

### **Enhancements**

N/A

### **Bugs Fixed**

- Fixed inaccurate counter value when using Modbus to start a pulse (E1210/E1212/E1213).
- Fixed opposite on/off pulse width display on web console (E1211/E1212/E1214).
- Fixed that the offset scaling value will reset after changing the Alias name (E1260).
- Fixed self-rebooting when entering URL in the browser for the configuration file.
- Fixed EDS file import connection error.
- Fixed failure when using save counter on power failure and reset counter at the same time (E1210/E1212/E1213).
- Fixed inaccurate counter value when using high frequency (E1210/E1212/E1213).
- Fixed that the trap community name is not included in the export file.
- Fixed that EtherNet/IP cannot use the "Set Attribute Single" service.
- Added an enable RESTful API setting in the configuration file.

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v3.0</b>	<b>Build: Build17111512</b>
<b>Release Date: Jan 16, 2018</b>	

### **Applicable Products**

ioLogik E1240-T, ioLogik E1240

### **Supported Operating Systems**

N/A

### **New Features**

- Added OPTIONS method for RESTful API.
- Added quick access URI for RESTful API.

### **Enhancements**

- Added SNMP Trap Community Setting on web console
- Mentioned max. 16 characters on password setting page

### **Bugs Fixed**

- Fixed DHCP lease time did not ask for extension when half of the lease time elapsed.
- Closed IP forwarding function (Port 0).
- Closed UDP Port 161 when SNMP agent is disabled.
- Fixed invalid token issue on login page when using Firefox.
- Fixed RESTful API header case-sensitive issue.
- Fixed invalid token issue on Modbus Address setting page.

### **Changes**

N/A

### **Notes**

- This version of firmware works with the ioSearch V2.0 or later only.
- Update only the next or the previous released firmware version to prevent from system failure.



<b>Version: v2.4</b>	<b>Build: Build16091211</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1240, ioLogik E1240-T

### **Supported Operating Systems**

N/A

### **New Features**

- Added EtherNet/IP protocol.
- Added RESTful API.
- Added new registers for Modbus/TCP protocol.
- Added new OIDs of SNMP protocol.
- Modbus, EtherNet/IP, RESTful Services can be disabled (default: enable).
- Added sending heartbeat to 9500 port of MX-AOPC UA Server after heartbeat function is enabled.
- Increased password length from 8 to 16.
- Added checking special character function for preventing from Cross-Site Scripting.
- Changed sending password from GET to POST method.

### **Enhancements**

N/A

### **Bugs Fixed**

- Fixed file transfer with Chrome browser issue (e.g. firmware update, configuration import or export).
- Fixed device may reboot when connecting to webpage after AI channel is disabled.
- Fixed wrong scaled value.

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v2.3</b>	<b>Build: Build16053018</b>
<b>Release Date: N/A</b>	

**Applicable Products**

ioLogik E1240, ioLogik E1240-T

**Supported Operating Systems**

N/A

**New Features**

- Improve protocol efficiency with ioLogik 2500 series .

**Enhancements**

N/A

**Bugs Fixed**

N/A

**Changes**

N/A

**Notes**

N/A



<b>Version: v2.2</b>	<b>Build: Build14121211</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1240-T, ioLogik E1240

### **Supported Operating Systems**

N/A

### **New Features**

- Support ioLogik 2500 expansion mode.

### **Enhancements**

N/A

### **Bugs Fixed**

- Unable to disable the P2P Heart beat interval.
- When the P2P client heartbeat is set to a value larger than 256, the time interval will be incorrect.

### **Changes**

N/A

### **Notes**

N/A



<b>Version: v2.0</b>	<b>Build: Build13041515</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1240, ioLogik E1240-T

### **Supported Operating Systems**

N/A

### **New Features**

- Support SNMP protocol.
- Add P2P heartbeat function .

### **Enhancements**

N/A

### **Bugs Fixed**

- P2P AI OnChange function should send packet to AO.
- AI mode setting should be able setting in webpage.

### **Changes**

N/A

### **Notes**

- This version of firmware works with the ioSearch V1.5 or later only.
- Use web console when upgrading firmware from V1.0 to V1.10.



<b>Version: v1.10</b>	<b>Build: Build12020809</b>
<b>Release Date: N/A</b>	

**Applicable Products**

ioLogik E1240, ioLogik E1240-T

**Supported Operating Systems**

N/A

**New Features**

- Added AI range 0-20mA and 4-20mA Burn-Out mode.

**Enhancements**

N/A

**Bugs Fixed**

N/A

**Changes**

N/A

**Notes**

N/A



<b>Version: v1.9</b>	<b>Build: Build11112413</b>
<b>Release Date: N/A</b>	

**Applicable Products**

ioLogik E1240, ioLogik E1240-T

**Supported Operating Systems**

N/A

**New Features**

N/A

**Enhancements**

- Ensured system to work properly after unstable power condition.

**Bugs Fixed**

- Peer-to-peer status on overview page should not show “disable” after complete peer to peer settings.

**Changes**

N/A

**Notes**

N/A



<b>Version: v1.8</b>	<b>Build: Build11092917</b>
<b>Release Date: N/A</b>	

### **Applicable Products**

ioLogik E1240, ioLogik E1240-T

### **Supported Operating Systems**

N/A

### **New Features**

- Added Locating I/O function in General Settings.
- Added Modbus address function code=0x08 for “ECHO” function.

### **Enhancements**

- Improved firmware upgrading speed.
- Removed Modbus/TCP ID checking mechanism.

### **Bugs Fixed**

- One DO/AO channel should only be peered by one DI/AI channel.
- No matter safe mode is triggered by Watchdog or Peer-to-peer, the DO/AO status under safe mode should be the same.

### **Changes**

N/A

### **Notes**

N/A