



Firmware for ioLogik E2200 Series (E2214) Release Notes

Version: v3.12.0	Build: Build16121512
Release Date: Jan 20, 2017	

Applicable Products

ioLogik E2214-T, ioLogik E2214

Supported Operating Systems

N/A

New Features

- Added checking special character function for preventing from Cross-Site Scripting.
- Added CSRF protection.
- Increased password length from 8 to 16.
- Added alive check for 9500 port to MX-AOPC UA Server.
- Counter value can be set through Modbus register.

Enhancements

N/A

Bugs Fixed

N/A

Changes

N/A

Notes

- This firmware version works with the ioAdmin v3.13 or later only.



Version: v3.11	Build: Build16021615
Release Date: N/A	

Applicable Products

ioLogik E2214-T, ioLogik E2214

Supported Operating Systems

N/A

New Features

- Advanced encryption algorithm on password in configuration file(compatible with ioAdmin v3.18 only).

Enhancements

N/A

Bugs Fixed

- Fixed unable to control output channel through MXview.

Changes

N/A

Notes

- This firmware version works with the ioAdmin v3.13 or later only.



Version: v3.10	Build: Build13092418
Release Date: N/A	

Applicable Products

ioLogik E2214, ioLogik E2214-T

Supported Operating Systems

N/A

New Features

N/A

Enhancements

N/A

Bugs Fixed

- Web page may not load/open when connecting to AOPC.
- CGI command causing overflow issue while sending commands to Web Server.
- Inconsistent idle time out initial value between the Remote Action Server and the other server. They are the same now.
- Continue writing flash while using DNS.
- After updating the device's firmware through web page, the device will need to be cold-restarted to complete the process.

Changes

N/A

Notes

- This firmware version works with the ioAdmin v3.13 or later only.