



## Firmware for ioLogik R1200 Series (R1242) Release Notes

<b>Version: v1.2</b>	<b>Build: Build16012218</b>
<b>Release Date: Apr 06, 2016</b>	

### Applicable Products

ioLogik R1241-T, ioLogik R1241

### Supported Operating Systems

N/A

### New Features

N/A

### Enhancements

N/A

### Bugs Fixed

- Fixed bit register unable to return data length issue.
- Fixed password not working issue.
- Fixed exception response without CRC.
- Fixed AO raw data from 0-65535 to 0-4095.

### Changes

N/A

### Notes

- Use ioSearch V1.12 to update ioLogik R1241 firmware from V1.0/V1.1 to V1.2. DO NOT use ioSearch V1.14 or later to configure ioLogik R1241 with V1.0/V1.1 firmware.
- Modbus master program needs to change AO raw data from 0-65535 to 0-4095 before ioLogik R1241 firmware is updated from V1.0/V1.1 to V1.2.



<b>Version: v1.0</b>	<b>Build: Build13031519</b>
<b>Release Date: N/A</b>	

**Applicable Products**

ioLogik R1241, ioLogik R1241-T

**Supported Operating Systems**

N/A

**New Features**

- New release.

**Enhancements**

N/A

**Bugs Fixed**

N/A

**Changes**

N/A

**Notes**

N/A